

処分した一般廃棄物の各月ごとにおける種類及び数量

(単位 トン)

年 月	種類	処 分 量
令和6年 4月	可燃物	7,864
令和6年 5月		10,218
令和6年 6月		10,529
令和6年 7月		9,660
令和6年 8月		9,579
令和6年 9月		8,699
令和6年 10月		4,762
令和6年 11月		9,700
令和6年 12月		9,844
令和7年 1月		10,245
令和7年 2月		9,668
令和7年 3月		10,272

排ガス測定結果

* 値はすべて酸素12%換算濃度

測定位置: 1号炉煙突

測定日	硫黄酸化物 濃度 (ppm)	塩化水素 濃度 (mg/Nm ³)	窒素酸化物 濃度 (ppm)	ばいじん (g/Nm ³)	ダイオキシン 類濃度 (ng-TEQ/m ³ N)	報告日
6月24日	7	13	32	0.001未満	—	7月24日
8月23日	5	16	43	0.001未満	—	9月27日
9月5日	—	—	—	—	0	10月4日
1月7日	7	15	37	0.001未満	—	1月31日
2月25日	4	9	36	0.001未満	—	3月19日

測定位置: 2号炉煙突

測定日	硫黄酸化物 濃度 (ppm)	塩化水素 濃度 (mg/Nm ³)	窒素酸化物 濃度 (ppm)	ばいじん (g/Nm ³)	ダイオキシン 類濃度 (ng-TEQ/m ³ N)	報告日
4月22日	6	10	31	0.001未満	—	5月22日
5月17日	—	—	—	—	0.000011	6月24日
6月24日	5	16	40	0.001未満	—	7月24日
11月5日	8	38	55	0.001未満	—	12月5日
1月7日	5	10	33	0.001未満	—	1月31日

測定位置: 3号炉煙突

測定日	硫黄酸化物 濃度 (ppm)	塩化水素 濃度 (mg/Nm ³)	窒素酸化物 濃度 (ppm)	ばいじん (g/Nm ³)	ダイオキシン 類濃度 (ng-TEQ/m ³ N)	報告日
5月21日	6	11	33	0.001未満	—	6月20日
8月23日	6	13	35	0.001未満	—	9月27日
9月5日	—	—	—	—	0	10月4日
11月5日	5	12	38	0.001未満	—	12月5日
2月25日	6	16	30	0.001未満	—	3月19日

[illegible]

	1号炉						2号炉			3号炉			備 考
日	燃烧温度 (℃)		ハグフィルタ 入口温度 (℃)		一酸化炭 素濃度 (ppm)		燃烧温度 (℃)	ハグフィルタ 入口温度 (℃)	一酸化炭 素濃度 (ppm)	燃烧温度 (℃)	ハグフィルタ 入口温度 (℃)	一酸化炭 素濃度 (ppm)	
1	停止		停止		停止		964	172	8	停止	停止	停止	
2							980	172	9				
3							984	172	7				
4							978	173	6				
5							969	174	7				
6							990	174	10				
7							959	173	7	↓	↓	↓	
8							953	173	6	982	171	7	
9							956	173	7	992	171	8	
10							955	172	10	1002	171	9	
11							936	172	3	1002	172	5	
12							937	173	5	995	172	7	
13							917	172	6	987	172	4	
14							936	172	5	1000	172	6	
15							925	173	5	984	173	6	
16							921	173	7	998	173	7	
17							918	173	8	994	173	8	
18							916	173	5	996	173	7	
19							922	173	4	989	172	6	
20							914	173	6	981	172	8	
21							914	173	7	991	172	11	
22							905	173	10	982	173	9	
23							914	173	9	989	173	11	
24							918	173	9	995	173	8	
25							934	172	4	997	172	5	
26							910	173	5	974	173	6	
27							915	173	7	974	173	7	
28							909	173	6	977	173	6	
29							913	173	4	980	173	5	
30							902	174	8	984	173	7	
31	↓		↓		↓		912	174	8	985	172	7	

[illegible]

排ガス温度等連続測定記録

	1号炉			2号炉			3号炉			備 考
日	燃烧温度 (℃)	ハグフィルタ 入口温度 (℃)	一酸化炭 素濃度 (ppm)	燃烧温度 (℃)	ハグフィルタ 入口温度 (℃)	一酸化炭 素濃度 (ppm)	燃烧温度 (℃)	ハグフィルタ 入口温度 (℃)	一酸化炭 素濃度 (ppm)	
1	868	171	6	871	169	3	停止	停止	停止	
2	877	171	5	879	169	3				
3	871	172	5	863	169	3				
4	877	171	7	869	169	4				
5	877	171	5	885	169	4				
6	882	171	5	892	169	3				
7	872	170	6	878	169	2				
8	877	170	11	886	169	10				
9	880	170	8	887	168	9				
10	813	165	10	830	164	10				
11	821	163	7	862	161	5				
12	828	160	6	852	157	8				
13	834	159	8	856	157	7				
14	841	159	5	886	156	5				
15	832	159	5	872	156	2				
16	831	159	9	858	156	5				
17	832	160	8	857	157	5				
18	835	159	10	871	156	8				
19	825	159	12	862	156	9				
20	837	160	9	872	156	5				
21	845	160	3	877	156	2				
22	867	165	6	890	163	7				
23	868	165	7	887	164	7				
24	877	165	6	909	163	4				
25	870	165	9	905	163	8				
26	880	165	11	907	163	9				
27	879	165	5	900	164	3				
28	890	166	4	883	164	2				
29	882	166	6	883	164	6				
30	877	166	8	887	164	9				
31	871	165	7	888	164	7	▼	▼	▼	

排ガス温度等連続測定記録

	1号炉			2号炉			3号炉			備 考
日	燃烧温度 (℃)	ハグフィルタ 入口温度 (℃)	一酸化炭 素濃度 (ppm)	燃烧温度 (℃)	ハグフィルタ 入口温度 (℃)	一酸化炭 素濃度 (ppm)	燃烧温度 (℃)	ハグフィルタ 入口温度 (℃)	一酸化炭 素濃度 (ppm)	
1	886	164	6	883	164	8	停止	停止	停止	
2	890	164	7	886	164	7				
3	894	163	5	904	164	5				
4	862	164	4	889	164	3				
5	866	165	6	887	164	8				
6	878	165	8	893	164	8				
7	882	166	5	903	164	4				
8	892	165	8	898	164	7				
9	888	165	5	900	164	7				
10	889	165	5	916	163	4				
11	874	166	4	889	164	5				
12	890	165	6	899	163	6				
13	897	165	4	901	163	6				
14	891	165	4	904	163	2				
15	890	165	5	917	162	4				
16	902	165	6	907	163	8				
17	877	165	5	905	163	2				
18	866	165	4	888	163	6				
19	876	164	8	892	163	9				
20	844	161	6	866	161	5	▼	▼	▼	
21	853	164	7	停止	停止	停止	870	168	23	
22	873	165	6				870	169	23	
23	875	165	6				910	168	20	
24	871	165	4				908	168	13	
25	857	165	6				895	169	10	
26	820	157	15				871	161	16	
27	853	156	11				865	161	15	
28	826	157	16				875	160	22	
29	850	158	10				897	159	18	
30	858	158	11				906	161	13	
31	851	158	5	▼	▼	▼	913	160	7	

[illegible]

排ガス温度等連続測定記録

	1号炉			2号炉						3号炉			備 考
日	燃烧温度 (℃)	バグフィルタ 入口温度 (℃)	一酸化炭 素濃度 (ppm)	燃烧温度 (℃)	バグフィルタ 入口温度 (℃)	一酸化炭 素濃度 (ppm)		燃烧温度 (℃)	バグフィルタ 入口温度 (℃)	一酸化炭 素濃度 (ppm)			
1	880	170	8	停止		停止		停止		975	171	11	
2	867	170	9							980	172	15	
3	863	170	5							952	172	9	
4	865	170	5							966	172	7	
5	866	170	5							960	171	7	
6	860	170	7							966	172	10	
7	870	171	6							968	172	8	
8	869	171	8							979	172	11	
9	875	171	6							991	172	9	
10	877	171	8							988	172	11	
11	883	170	7							988	171	12	
12	880	171	5							988	173	6	
13	停止	停止	停止							停止	停止	停止	
14													
15													
16													
17													
18													
19													
20													
21													
22													
23													
24													
25													
26													
27													
28													
29													
30													
31													

排ガス温度等連続測定記録

	1号炉						2号炉			3号炉			備 考
日	燃烧温度 (℃)		ハグフィルタ 入口温度 (℃)		一酸化炭 素濃度 (ppm)		燃烧温度 (℃)	ハグフィルタ 入口温度 (℃)	一酸化炭 素濃度 (ppm)				
1	停止		停止		停止		876	173	16	972	170	8	
2							891	173	14	966	170	10	
3							892	172	13	983	168	8	
4							909	172	14	985	167	6	
5							912	172	13	975	168	8	
6							926	172	11	998	168	7	
7							911	172	12	1000	166	10	
8							921	171	11	1002	166	11	
9							922	171	8	1002	166	6	
10							922	171	10	993	167	13	
11							918	171	10	990	169	8	
12							923	172	16	982	167	8	
13							909	171	8	972	165	9	
14							916	171	8	972	168	8	
15							916	171	8	980	168	8	
16							924	172	6	983	170	6	
17							918	173	3	975	173	5	
18							911	172	5	974	172	5	
19							926	172	5	986	171	5	
20							932	172	6	970	171	6	
21							935	172	7	974	170	6	
22							943	172	6	978	169	5	
23							940	171	4	978	168	4	
24							927	172	5	968	171	4	
25							940	171	9	964	169	12	
26							937	172	8	957	171	12	
27							929	172	5	972	169	6	
28							932	171	5	983	167	5	
29							941	172	5	972	170	5	
30							931	172	5	976	170	8	
	▼		▼		▼								

排ガス温度等連続測定記録

	1号炉						2号炉			3号炉			備 考
日	燃烧温度 (℃)		バグフィルタ 入口温度 (℃)		一酸化炭 素濃度 (ppm)		燃烧温度 (℃)	バグフィルタ 入口温度 (℃)	一酸化炭 素濃度 (ppm)				
1	停止		停止		停止		907	172	9	961	169	9	
2							912	172	8	968	170	7	
3							918	172	7	971	170	6	
4							913	172	8	962	172	8	
5							924	171	7	968	171	6	
6							931	171	6	981	171	7	
7							926	171	5	990	171	6	
8							940	171	6	985	172	9	
9							935	170	8	985	169	8	
10							935	170	8	971	168	8	
11							920	170	7	973	168	8	
12							901	171	8	972	170	9	
13							921	171	12	969	171	11	
14							922	171	5	974	171	6	
15							921	172	5	967	171	10	
16							923	171	7	983	169	7	
17							924	170	10	991	168	11	
18							920	170	9	983	168	10	
19							935	169	11	981	167	10	
20							936	170	8	991	168	9	
21							934	171	6	984	167	7	
22							920	171	4	972	167	6	
23							935	170	10	976	163	10	
24	▼		▼		▼		903	166	5	959	155	5	
25	864		168		24		894	171	6	停止	停止	停止	
26	850		170		28		917	171	8				
27	停止		停止		停止		959	173	12				
28							978	173	5				
29	▼		▼		▼		959	171	7				
30	897		169		32		964	169	7				
31	897		167		51		958	169	8	▼	▼	▼	

排ガス温度等連続測定記録

	1号炉			2号炉			3号炉			備 考
日	燃烧温度 (℃)	バグフィルタ 入口温度 (℃)	一酸化炭 素濃度 (ppm)	燃烧温度 (℃)	バグフィルタ 入口温度 (℃)	一酸化炭 素濃度 (ppm)	燃烧温度 (℃)	バグフィルタ 入口温度 (℃)	一酸化炭 素濃度 (ppm)	
1	886	168	35	951	168	8	停止	停止	停止	
2	899	168	25	972	168	8				
3	887	168	9	961	169	4				
4	879	169	7	924	170	3				
5	892	169	7	929	169	3				
6	875	169	8	917	170	4				
7	896	168	8	940	170	4				
8	883	168	8	946	170	5				
9	881	167	9	935	170	4				
10	894	167	7	927	169	5				
11	895	167	6	929	170	3				
12	880	167	4	918	170	3				
13	902	166	5	939	170	2				
14	907	166	5	910	171	7				
15	890	166	7	918	170	6				
16	909	166	4	924	170	4				
17	880	166	6	918	170	6				
18	921	165	3	928	170	4				
19	917	165	4	938	170	3				
20	912	166	6	939	170	8				
21	907	165	6	927	170	4				
22	904	165	4	930	170	3				
23	906	165	5	930	170	5				
24	913	166	5	931	170	4				
25	920	165	2	956	170	2				
26	903	165	3	937	170	3				
27	892	167	6	918	171	6				
28	901	166	6	927	170	7				
29	895	166	6	905	171	5				
30	921	166	5	924	170	5				
31	912	166	4	921	170	6	▼	▼	▼	

排ガス温度等連続測定記録

	1号炉			2号炉			3号炉						備 考
日	燃烧温度 (℃)	パグフィルタ 入口温度 (℃)	一酸化炭素濃度 (ppm)	燃烧温度 (℃)	パグフィルタ 入口温度 (℃)	一酸化炭素濃度 (ppm)	燃烧温度 (℃)		パグフィルタ 入口温度 (℃)		一酸化炭素濃度 (ppm)		
1	924	168	5	939	169	5	停止		停止		停止		
2	911	168	3	943	170	4							
3	893	168	5	929	170	9							
4	904	167	5	928	170	9							
5	907	167	3	923	171	8							
6	914	167	5	929	170	6							
7	908	167	6	913	169	8							
8	911	166	4	916	170	6							
9	904	166	4	923	169	5							
10	901	166	5	913	170	8							
11	910	166	3	930	169	5							
12	900	168	4	919	169	6							
13	913	167	6	934	170	8							
14	912	167	8	922	170	7							
15	904	167	2	923	170	4							
16	891	168	3	915	171	4							
17	924	167	4	930	165	6							
18	894	160	4	895	158	6							
19	907	164	5	停止	停止	停止	957		167		10		
20	897	166	5				967		169		8		
21	900	165	6				986		169		8		
22	918	165	4				998		168		7		
23	894	166	3				995		169		7		
24	896	166	4				1000		167		7		
25	905	165	6				1003		167		12		
26	894	166	4				993		168		8		
27	897	166	6				1001		168		7		
28	922	167	4				1007		167		7		

排ガス温度等連続測定記録

日	1号炉			2号炉				3号炉			備 考
	燃烧温度 (℃)	バグフィルタ 入口温度 (℃)	一酸化炭 素濃度 (ppm)	燃烧温度 (℃)	バグフィルタ 入口温度 (℃)	一酸化炭 素濃度 (ppm)		燃烧温度 (℃)	バグフィルタ 入口温度 (℃)	一酸化炭 素濃度 (ppm)	
1	905	167	3	停止	停止	停止		998	168	5	
2	893	169	3					987	169	5	
3	913	168	3					988	168	5	
4	912	167	4					978	169	5	
5	889	168	3					961	170	6	
6	906	166	3					979	170	5	
7	931	167	4					988	169	4	
8	923	167	3					988	169	5	
9	889	168	3					979	170	6	
10	911	168	8					992	169	11	
11	912	168	6					987	171	8	
12	898	169	4					970	172	5	
13	895	168	5					981	169	5	
14	903	167	5					988	169	7	
15	895	167	3					975	170	4	
16	879	168	3					956	172	4	
17	910	168	5					986	169	5	
18	918	167	4					997	169	9	
19	878	168	4					962	167	4	
20	897	167	6					1001	167	4	
21	898	167	8					1009	168	10	
22	894	168	6					1001	169	5	
23	888	168	3					974	172	4	
24	913	168	8					992	169	9	
25	915	167	11					994	169	11	
26	898	167	8					981	169	11	
27	887	168	7					980	169	14	
28	891	168	10					1000	168	16	
29	907	166	6					998	168	6	
30	909	166	5					996	168	9	
31	908	165	6	↓	↓	↓		1011	167	12	

[illegible]

排ガス連続測定記録

日	1号炉			2号炉			3号炉			備 考
	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)	
1	停止	停止	停止	8	10	40	停止	停止	停止	
2				8	9	40				
3				8	10	40				
4				8	10	39				
5				8	9	41				
6				9	8	41				
7				8	10	42	↓	↓	↓	
8				8	9	40	8	11	37	
9				8	10	40	8	11	40	
10				8	10	40	8	11	39	
11				8	11	41	8	12	40	
12				8	10	39	8	11	39	
13				6	11	41	7	12	41	
14				6	12	41	7	12	41	
15				7	12	41	7	13	39	
16				7	12	39	7	12	40	
17				7	11	41	7	12	40	
18				8	12	41	8	12	40	
19				7	11	40	8	12	39	
20				7	11	40	8	12	40	
21				7	11	39	7	11	40	
22				7	12	39	7	11	39	
23				7	11	40	7	11	40	
24				7	12	40	8	13	41	
25				8	13	40	8	12	39	
26				7	12	39	7	11	39	
27				6	11	40	6	11	40	
28				6	12	40	7	12	40	
29				7	12	41	7	12	41	
30				6	12	40	6	12	41	
31	↓	↓	↓	7	12	41	7	12	39	

[illegible]

排ガス連続測定記録

日	1号炉			2号炉			3号炉						備 考
	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)	
1	6	11	40	4	9	40	停止	停止	停止				
2	5	12	39	4	9	40							
3	6	13	39	5	10	40							
4	6	13	40	5	11	41							
5	6	13	40	6	10	41							
6	7	13	41	6	11	42							
7	7	13	41	6	11	41							
8	6	11	39	6	9	39							
9	6	12	41	6	9	41							
10	6	12	34	6	9	39							
11	5	9	39	6	8	41							
12	4	9	40	3	6	41							
13	6	10	41	5	7	40							
14	6	10	42	6	7	41							
15	5	10	40	5	7	40							
16	5	10	39	3	6	40							
17	6	10	41	4	5	41							
18	5	9	39	4	6	40							
19	5	10	40	4	7	40							
20	6	11	41	6	8	40							
21	6	12	40	5	8	39							
22	5	11	38	5	9	39							
23	5	12	40	5	10	39							
24	7	13	40	7	11	40							
25	5	11	39	5	9	40							
26	6	12	39	6	10	40							
27	7	13	40	6	11	40							
28	7	12	39	7	11	38							
29	6	12	39	6	10	40							
30	6	12	39	6	11	39							
31	5	11	38	6	9	40	▼	▼	▼				

排ガス連続測定記録

日	1号炉			2号炉			3号炉			備 考
	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)	
1	6	11	39	6	10	38	停止	停止	停止	
2	5	10	40	6	10	40				
3	7	11	40	7	11	39				
4	6	11	39	6	11	40				
5	5	11	40	5	10	40				
6	7	12	40	6	10	41				
7	6	11	40	6	11	39				
8	6	11	39	6	10	40				
9	6	12	40	6	10	39				
10	7	12	42	7	11	41				
11	7	12	37	7	10	40				
12	6	12	41	7	10	40				
13	7	11	40	7	10	40				
14	7	11	39	7	11	41				
15	7	12	38	7	10	40				
16	7	12	36	7	10	40				
17	7	11	38	7	11	41				
18	7	11	40	7	10	39				
19	6	12	35	7	10	39				
20	5	11	35	6	10	42	▼	▼	▼	
21	5	11	45	停止	停止	停止	8	9	41	
22	5	11	39				8	9	40	
23	6	11	41				8	9	40	
24	6	12	39				8	9	41	
25	6	11	39				8	9	40	
26	3	6	37				6	7	38	
27	5	7	42				7	8	41	
28	6	9	39				7	8	38	
29	5	8	40				6	8	40	
30	5	9	41				6	8	40	
31	6	11	40	▼	▼	▼	6	8	39	

日	1号炉			2号炉						3号炉			備 考
	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)		硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)			
1	6	9	39	停止		停止		停止		7	8	40	
2	5	9	40							6	8	39	
3	5	9	40							6	8	38	
4	6	9	40							6	8	41	
5	6	9	40							6	7	39	
6	6	9	40							6	7	40	
7	6	10	39							6	8	40	
8	6	10	41							6	8	40	
9	5	9	40							6	8	40	
10	5	9	40							6	8	40	
11	5	9	40							6	8	40	
12	5	9	40							6	8	41	
13	5	9	40							6	8	40	
14	6	10	39							7	8	36	
15	6	10	39							6	9	39	
16	6	13	38							7	11	40	
17	6	12	40							7	11	40	
18	7	12	40							8	10	40	
19	7	12	41							8	10	40	
20	7	12	39							8	11	40	
21	7	13	39							8	10	40	
22	7	12	40							7	10	39	
23	6	13	39							7	12	41	
24	6	12	40							7	11	40	
25	7	12	38							8	10	40	
26	7	12	41							8	10	40	
27	7	12	40							8	10	39	
28	7	13	40							9	11	42	
29	8	11	39							8	10	40	
30	6	11	39							8	10	41	
				▼	▼	▼							

排ガス連続測定記録

日	1号炉			2号炉						3号炉			備 考
	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)	
1	6	12	41	停止	停止	停止	7	10	41				
2	7	12	40				8	10	39				
3	6	11	40				7	10	40				
4	6	12	40				7	11	41				
5	6	13	38				8	12	40				
6	6	11	40				8	10	41				
7	5	11	39				7	11	40				
8	6	13	40				7	11	40				
9	7	13	41				7	11	41				
10	6	13	39				7	11	39				
11	6	11	41				7	11	41				
12	7	14	42				8	14	40				
13	停止	停止	停止				停止	停止	停止				
14													
15													
16													
17													
18													
19													
20													
21													
22													
23													
24													
25													
26													
27													
28													
29													
30				↓	↓	↓	↓	↓	↓				
31	↓	↓	↓	8	12	44	7	11	28				

日	1号炉						2号炉			3号炉			備 考
	硫黄酸化 物濃度 (ppm)		塩化水 素濃度 (ppm)		窒素酸化 物濃度 (ppm)		硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)	
1	停止		停止		停止		8	12	37	7	11	41	
2							8	12	41	7	12	40	
3							8	11	41	7	11	40	
4							8	11	41	7	12	41	
5							8	11	40	7	12	41	
6							8	9	40	7	11	40	
7							8	9	41	8	10	42	
8							8	9	40	8	10	41	
9							8	10	39	7	11	40	
10							8	9	40	8	9	40	
11							8	10	40	7	11	41	
12							8	9	39	8	11	42	
13							8	10	40	7	12	40	
14							8	10	38	7	11	42	
15							7	10	40	8	10	40	
16							8	10	41	8	12	39	
17							8	9	41	8	11	40	
18							7	10	40	7	11	41	
19							7	10	40	8	11	42	
20							7	9	40	7	11	37	
21							7	9	41	7	10	39	
22							8	10	40	7	10	39	
23							8	9	41	8	10	41	
24							7	10	41	7	11	40	
25							7	9	39	7	10	39	
26							7	9	39	7	10	41	
27							8	11	40	7	11	39	
28							7	11	40	6	11	40	
29							7	10	41	7	12	40	
30		▼		▼		▼	7	11	40	7	12	40	

排ガス連続測定記録

日	1号炉			2号炉			3号炉			備 考
	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)	
1	停止	停止	停止	8	10	39	8	11	41	
2				7	10	40	6	11	40	
3				7	11	39	7	12	39	
4				7	11	38	7	12	39	
5				7	11	40	7	11	40	
6				7	11	41	7	11	39	
7				7	13	41	7	13	40	
8				7	11	40	8	10	40	
9				7	10	40	7	10	41	
10				7	10	40	7	10	40	
11				7	11	39	7	10	38	
12				7	10	40	7	10	39	
13				7	9	41	7	10	41	
14				8	11	40	7	10	40	
15				8	11	41	8	10	39	
16				7	11	41	7	10	40	
17				7	11	40	7	10	40	
18				8	12	40	8	11	41	
19				7	11	40	7	10	39	
20				7	11	40	7	11	41	
21				8	12	41	7	12	39	
22				7	12	40	7	11	39	
23				7	11	41	7	11	40	
24	↓	↓	↓	7	9	41	6	8	40	
25	8	9	34	7	12	40	停止	停止	停止	
26	9	10	40	7	12	40				
27	停止	停止	停止	9	12	40				
28				8	13	40				
29	↓	↓	↓	8	12	40				
30	9	9	38	8	10	42				
31	9	8	37	9	10	38	↓	↓	↓	

排ガス連続測定記録

日	1号炉			2号炉			3号炉			備 考
	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)	
1	9	7	39	8	10	40	停止	停止	停止	
2	9	7	39	8	10	41				
3	8	8	40	7	11	39				
4	7	11	40	6	13	39				
5	8	10	40	7	12	39				
6	7	11	40	5	11	40				
7	7	11	41	6	11	41				
8	8	11	40	7	11	41				
9	7	12	40	7	12	40				
10	7	12	40	7	11	41				
11	8	12	40	7	12	40				
12	8	11	39	7	11	40				
13	7	12	40	7	12	41				
14	7	11	41	6	12	41				
15	7	12	39	7	12	40				
16	7	11	40	7	12	39				
17	7	13	39	6	11	40				
18	7	14	40	7	13	39				
19	7	12	40	7	13	40				
20	7	13	39	7	12	41				
21	7	13	41	7	13	41				
22	8	13	40	7	12	40				
23	7	11	39	6	11	40				
24	7	11	40	6	11	41				
25	8	13	41	7	12	40				
26	7	12	39	7	12	40				
27	6	12	38	6	11	39				
28	7	13	40	7	12	40				
29	7	13	41	6	13	39				
30	7	11	41	7	13	40				
31	7	12	39	6	11	40	↓	↓	↓	

[illegible]

排ガス連続測定記録

日	1号炉			2号炉						3号炉			備 考
	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)	硫黄酸化 物濃度 (ppm)	塩化水 素濃度 (ppm)	窒素酸化 物濃度 (ppm)	
1	7	14	41	停止	停止	停止	7	13	39				
2	7	13	39				7	14	38				
3	6	13	39				6	13	41				
4	6	13	41				7	15	41				
5	6	12	41				6	12	39				
6	7	11	39				5	11	39				
7	6	9	39				6	10	40				
8	7	11	40				6	11	40				
9	7	11	39				6	12	40				
10	7	11	40				6	11	40				
11	7	11	41				7	11	39				
12	7	12	39				7	12	40				
13	7	11	39				7	12	40				
14	7	12	40				8	13	41				
15	7	12	39				7	13	40				
16	7	11	38				7	13	40				
17	6	11	39				6	12	40				
18	7	11	40				7	12	39				
19	7	11	44				6	12	38				
20	7	11	37				7	12	41				
21	7	10	40				7	11	40				
22	7	12	39				7	12	41				
23	8	11	40				7	12	40				
24	7	10	41				7	11	40				
25	8	9	39				8	12	39				
26	7	10	39				7	10	39				
27	7	11	40				8	11	39				
28	8	11	40				8	11	39				
29	7	11	40				7	11	39				
30	8	11	39				8	11	40				
31	7	11	40	↓	↓	↓	8	11	39				

冷却設備及びガス処理設備に堆積したばいじんの除去を行った年月日

西クリーンセンター

令和6年4月

冷 却 設 備				ガス処理設備			
除 去 方 法				除 去 方 法			
日	1号炉	2号炉	3号炉	日	1号炉	2号炉	3号炉
1	①	停止	①	1	①	停止	①
2	①		①	2	①		①
3	①		①	3	①		①
4	①		①	4	①		①
5	①		①	5	①		①
6	①		①	6	①		①
7	①		①	7	①		①
8	①		①	8	①		①
9	①		①	9	①		①
10	①		①	10	①		①
11	①		①	11	①		①
12	①		①	12	①		①
13	①		①	13	①		①
14	①		①	14	①		①
15	①		①	15	①		①
16	①	↓	停止	16	①	↓	停止
17	停止	①		17	停止	①	
18		①		18		①	
19		①		19		①	
20		①		20		①	
21		①		21		①	
22		①		22		①	
23		①		23		①	
24	②	①		24	②	①	
25		①		25		①	
26		①		26		①	
27		①		27		①	
28		①		28		①	
29	②	①		29		①	
30	②↓	①	↓	30	↓	①	↓
31				31			
(※) ① スートブローによる除去 (毎日実行) ② 休炉点検時における除去				(※) ① バグフィルターの逆洗による除去 (毎日実行) ② 休炉点検時における除去			

冷却設備及びガス処理設備に堆積したばいじんの除去を行った年月日

西クリーンセンター

令和6年5月

冷 却 設 備				ガス処理設備			
除 去 方 法				除 去 方 法			
日	1号炉	2号炉	3号炉	日	1号炉	2号炉	3号炉
1	停止	①	停止	1	停止	停止	停止
2		①		2		①	
3		①	②	3		①	
4		①		4		①	
5		①		5		①	
6		①		6		①	
7		①	↓	7	②	①	↓
8		①	①	8	②	①	①
9		①	①	9		①	①
10		①	①	10		①	①
11		①	①	11		①	①
12		①	①	12		①	①
13		①	①	13		①	①
14		①	①	14		①	①
15		①	①	15		①	①
16		①	①	16		①	①
17		①	①	17		①	①
18		①	①	18		①	①
19		①	①	19		①	①
20		①	①	20		①	①
21		①	①	21		①	①
22		①	①	22		①	①
23		①	①	23		①	①
24		①	①	24		①	①
25		①	①	25		①	①
26		①	①	26		①	①
27		①	①	27		①	①
28		①	①	28		①	①
29		①	①	29		①	①
30		①	①	30		①	①
31	↓	①	①	31	↓	①	①
(※) ① スートブローによる除去 (毎日実行) ② 休炉点検時における除去				(※) ① バグフィルターの逆洗による除去 (毎日実行) ② 休炉点検時における除去			

冷却設備及びガス処理設備に堆積したばいじんの除去を行った年月日

西クリーンセンター

令和6年6月

冷 却 設 備				ガス処理設備			
除 去 方 法				除 去 方 法			
日	1号炉	2号炉	3号炉	日	1号炉	2号炉	3号炉
1	停止	①	①	1	停止	停止	①
2		①	①	2		①	①
3		①	①	3		①	①
4		①	①	4		①	①
5		①	①	5		①	①
6		①	①	6		①	①
7		①	①	7		①	①
8		①	①	8		①	①
9		①	①	9		①	①
10		①	①	10		①	①
11		①	①	11		①	①
12		①	①	12		①	①
13		①	①	13		①	①
14		①	①	14		①	①
15		①	①	15		①	①
16		①	①	16		①	①
17		①	①	17		①	①
18	↓	①	①	18	↓	①	①
19	①	①	停止	19	①	①	停止
20	①	①		20	①	①	
21	①	①		21	①	①	
22	①	①		22	①	①	
23	①	①		23	①	①	
24	①	①		24	①	①	
25	①	①		25	①	①	
26	①	①	②	26	①	①	
27	①	①		27	①	①	
28	①	①		28	①	①	②
29	①	①		29	①	①	
30	①	①		30	①	①	
31	①	①	↓	31	①	①	↓
(※) ① スートブローによる除去 (毎日実行) ② 休炉点検時における除去				(※) ① バグフィルターの逆洗による除去 (毎日実行) ② 休炉点検時における除去			

冷却設備及びガス処理設備に堆積したばいじんの除去を行った年月日

西クリーンセンター

令和6年7月

冷 却 設 備				ガス処理設備			
除 去 方 法				除 去 方 法			
日	1号炉	2号炉	3号炉	日	1号炉	2号炉	3号炉
1	①	①	停止	1	①	①	停止
2	①	①		2	①	①	
3	①	①		3	①	①	
4	①	①		4	①	①	
5	①	①		5	①	①	
6	①	①		6	①	①	
7	①	①		7	①	①	
8	①	①	②	8	①	①	
9	①	①	②	9	①	①	
10	①	①		10	①	①	
11	①	①		11	①	①	
12	①	①		12	①	①	
13	①	①		13	①	①	
14	①	①		14	①	①	
15	①	①		15	①	①	②
16	①	①		16	①	①	②
17	①	①		17	①	①	
18	①	①		18	①	①	
19	①	①		19	①	①	
20	①	①		20	①	①	
21	①	①		21	①	①	
22	①	①		22	①	①	
23	①	①		23	①	①	
24	①	①		24	①	①	
25	①	①		25	①	①	
26	①	①		26	①	①	
27	①	①		27	①	①	
28	①	①		28	①	①	
29	①	①		29	①	①	
30	①	①		30	①	①	
31	①	①	↓	31	①	①	↓
(※) ① スートブローによる除去 (毎日実行) ② 休炉点検時における除去				(※) ① バグフィルターの逆洗による除去 (毎日実行) ② 休炉点検時における除去			

冷却設備及びガス処理設備に堆積したばいじんの除去を行った年月日

西クリーンセンター

令和6年8月

冷 却 設 備				ガス処理設備			
	除 去 方 法				除 去 方 法		
日	1号炉	2号炉	3号炉	日	1号炉	2号炉	3号炉
1	①	①	停止	1	①	①	停止
2	①	①		2	①	①	
3	①	①		3	①	①	
4	①	①		4	①	①	
5	①	①		5	①	①	
6	①	①		6	①	①	
7	①	①		7	①	①	
8	①	①		8	①	①	
9	①	①		9	①	①	
10	①	①		10	①	①	
11	①	①		11	①	①	
12	①	①		12	①	①	
13	①	①		13	①	①	
14	①	①		14	①	①	
15	①	①		15	①	①	
16	①	①		16	①	①	
17	①	①		17	①	①	
18	①	①		18	①	①	
19	①	①		19	①	①	
20	①	①	↓	20	①	①	↓
21	①	停止	①	21	①	停止	①
22	①		①	22	①		①
23	①		①	23	①		①
24	①		①	24	①		①
25	①		①	25	①		①
26	①	②	①	26	①		①
27	①	②	①	27	①		①
28	①		①	28	①	②	①
29	①		①	29	①	②	①
30	①		①	30	①		①
31	①	↓	①	31	①	↓	①
(※) ① スートブローによる除去 (毎日実行) ② 休炉点検時における除去				(※) ① バグフィルターの逆洗による除去 (毎日実行) ② 休炉点検時における除去			

冷却設備及びガス処理設備に堆積したばいじんの除去を行った年月日

西クリーンセンター

令和6年9月

冷 却 設 備				ガス処理設備			
	除 去 方 法				除 去 方 法		
日	1号炉	2号炉	3号炉	日	1号炉	2号炉	3号炉
1	①	停止	①	1	①	停止	①
2	①		①	2	①		①
3	①		①	3	①		①
4	①		①	4	①		①
5	①		①	5	①		①
6	①		①	6	①		①
7	①		①	7	①		①
8	①		①	8	①		①
9	①	②	①	9	①		①
10	①	②	①	10	①		①
11	①		①	11	①		①
12	①		①	12	①		①
13	①		①	13	①		①
14	①		①	14	①		①
15	①		①	15	①		①
16	①		①	16	①	②	①
17	①		①	17	①	②	①
18	①		①	18	①	②	①
19	①		①	19	①	②	①
20	①		①	20	①	②	①
21	①		①	21	①		①
22	①		①	22	①		①
23	①		①	23	①		①
24	①		①	24	①		①
25	①		①	25	①		①
26	①		①	26	①		①
27	①		①	27	①		①
28	①		①	28	①		①
29	①		①	29	①		①
30	①	↓	①	30	①	↓	①
31				31			
(※) ① スートブローによる除去 (毎日実行) ② 休炉点検時における除去				(※) ① バグフィルターの逆洗による除去 (毎日実行) ② 休炉点検時における除去			

冷却設備及びガス処理設備に堆積したばいじんの除去を行った年月日

西クリーンセンター

令和6年10月

冷 却 設 備				ガス処理設備			
除 去 方 法				除 去 方 法			
日	1号炉	2号炉	3号炉	日	1号炉	2号炉	3号炉
1	①	停止	①	1	①	停止	①
2	①		①	2	①		①
3	①		①	3	①		①
4	①		①	4	①		①
5	①		①	5	①		①
6	①		①	6	①		①
7	①		①	7	①		①
8	①		①	8	①		①
9	①		①	9	①		①
10	①		①	10	①		①
11	①		①	11	①		①
12	①		①	12	①		①
13	停止		停止	13	停止		停止
14				14			
15				15			
16				16			
17				17			
18				18			
19				19			
20				20			
21			②	21			
22				22			②
23				23			②
24				24			②
25				25			
26				26			
27				27			
28	②			28			
29	②			29	②		
30	②			30	②		
31	↓	①	①	31	↓	①	①
(※) ① スートブローによる除去 (毎日実行) ② 休炉点検時における除去				(※) ① バグフィルターの逆洗による除去 (毎日実行) ② 休炉点検時における除去			

冷却設備及びガス処理設備に堆積したばいじんの除去を行った年月日

西クリーンセンター

令和6年11月

冷 却 設 備				ガス処理設備			
除 去 方 法				除 去 方 法			
日	1号炉	2号炉	3号炉	日	1号炉	2号炉	3号炉
1	停止	①	①	1	停止	①	①
2		①	①	2		①	①
3		①	①	3		①	①
4		①	①	4		①	①
5		①	①	5		①	①
6		①	①	6		①	①
7		①	①	7		①	①
8		①	①	8		①	①
9		①	①	9		①	①
10		①	①	10		①	①
11		①	①	11		①	①
12		①	①	12		①	①
13		①	①	13		①	①
14		①	①	14		①	①
15		①	①	15		①	①
16		①	①	16		①	①
17		①	①	17		①	①
18		①	①	18	②	①	①
19		①	①	19	②	①	①
20		①	①	20		①	①
21		①	①	21		①	①
22		①	①	22		①	①
23		①	①	23		①	①
24		①	①	24		①	①
25		①	①	25		①	①
26		①	①	26		①	①
27		①	①	27		①	①
28	②	①	①	28		①	①
29	②	①	①	29		①	①
30	▼	①	①	30	▼	①	①
31				31			
(※) ① スートブローによる除去 (毎日実行) ② 休炉点検時における除去				(※) ① バグフィルターの逆洗による除去 (毎日実行) ② 休炉点検時における除去			

冷却設備及びガス処理設備に堆積したばいじんの除去を行った年月日

西クリーンセンター

令和6年12月

冷 却 設 備				ガス処理設備			
除 去 方 法				除 去 方 法			
日	1号炉	2号炉	3号炉	日	1号炉	2号炉	3号炉
1	停止	①	①	1	停止	①	①
2		①	①	2		①	①
3		①	①	3		①	①
4		①	①	4		①	①
5		①	①	5		①	①
6		①	①	6		①	①
7		①	①	7		①	①
8		①	①	8		①	①
9		①	①	9		①	①
10		①	①	10		①	①
11		①	①	11		①	①
12		①	①	12		①	①
13		①	①	13		①	①
14		①	①	14		①	①
15		①	①	15		①	①
16		①	①	16		①	①
17		①	①	17		①	①
18		①	①	18		①	①
19		①	①	19		①	①
20		①	①	20		①	①
21		①	①	21		①	①
22		①	①	22		①	①
23		①	①	23		①	①
24	↓	①	①	24	↓	①	①
25	①	①	停止	25	①	①	停止
26	①	①		26	①	①	
27	停止	①		27	停止	①	
28	↓	①		28	↓	①	
29	↓	①		29	↓	①	
30	①	①		30	①	①	
31	①	①	↓	31	①	①	↓
(※) ① スートブローによる除去 (毎日実行) ② 休炉点検時における除去				(※) ① バグフィルターの逆洗による除去 (毎日実行) ② 休炉点検時における除去			

冷却設備及びガス処理設備に堆積したばいじんの除去を行った年月日

西クリーンセンター

令和7年1月

冷 却 設 備				ガス処理設備			
	除 去 方 法				除 去 方 法		
日	1号炉	2号炉	3号炉	日	1号炉	2号炉	3号炉
1	①	①	停止	1	①	①	停止
2	①	①		2	①	①	
3	①	①		3	①	①	
4	①	①		4	①	①	
5	①	①		5	①	①	
6	①	①	②	6	①	①	
7	①	①		7	①	①	
8	①	①		8	①	①	
9	①	①		9	①	①	
10	①	①		10	①	①	
11	①	①		11	①	①	
12	①	①		12	①	①	
13	①	①		13	①	①	
14	①	①		14	①	①	
15	①	①		15	①	①	
16	①	①	②	16	①	①	②
17	①	①		17	①	①	
18	①	①		18	①	①	
19	①	①		19	①	①	
20	①	①		20	①	①	
21	①	①		21	①	①	
22	①	①		22	①	①	
23	①	①		23	①	①	
24	①	①		24	①	①	
25	①	①		25	①	①	
26	①	①		26	①	①	
27	①	①		27	①	①	
28	①	①		28	①	①	
29	①	①		29	①	①	
30	①	①		30	①	①	
31	①	①	↓	31	①	①	↓
(※) ① スートブローによる除去 (毎日実行) ② 休炉点検時における除去				(※) ① バグフィルターの逆洗による除去 (毎日実行) ② 休炉点検時における除去			

冷却設備及びガス処理設備に堆積したばいじんの除去を行った年月日

西クリーンセンター

令和7年2月

冷 却 設 備				ガス処理設備			
除 去 方 法				除 去 方 法			
日	1号炉	2号炉	3号炉	日	1号炉	2号炉	3号炉
1	①	①	停止	1	①	①	停止
2	①	①		2	①	①	
3	①	①		3	①	①	②
4	①	①		4	①	①	②
5	①	①		5	①	①	
6	①	①		6	①	①	
7	①	①		7	①	①	
8	①	①		8	①	①	
9	①	①		9	①	①	
10	①	①		10	①	①	
11	①	①		11	①	①	
12	①	①		12	①	①	
13	①	①		13	①	①	
14	①	①		14	①	①	
15	①	①		15	①	①	
16	①	①		16	①	①	
17	①	①		17	①	①	
18	①	①	↓	18	①	①	↓
19	①	停止	①	19	①	停止	①
20	①		①	20	①		①
21	①		①	21	①		①
22	①		①	22	①		①
23	①		①	23	①		①
24	①	②	①	24	①		①
25	①		①	25	①		①
26	①		①	26	①		①
27	①		①	27	①		①
28	①	↓	①	28	①	↓	①
29				29			
30				30			
31				31			
(※) ① スートブローによる除去 (毎日実行) ② 休炉点検時における除去				(※) ① バグフィルターの逆洗による除去 (毎日実行) ② 休炉点検時における除去			

冷却設備及びガス処理設備に堆積したばいじんの除去を行った年月日

西クリーンセンター

令和7年3月

冷 却 設 備				ガス処理設備			
	除 去 方 法				除 去 方 法		
日	1号炉	2号炉	3号炉	日	1号炉	2号炉	3号炉
1	①	停止	①	1	①	停止	①
2	①		①	2	①		①
3	①		①	3	①	②	①
4	①		①	4	①		①
5	①		①	5	①		①
6	①		①	6	①		①
7	①		①	7	①		①
8	①		①	8	①		①
9	①		①	9	①		①
10	①		①	10	①		①
11	①		①	11	①		①
12	①		①	12	①		①
13	①		①	13	①		①
14	①		①	14	①		①
15	①		①	15	①		①
16	①		①	16	①		①
17	①		①	17	①		①
18	①	②	①	18	①		①
19	①		①	19	①		①
20	①		①	20	①		①
21	①		①	21	①		①
22	①		①	22	①		①
23	①		①	23	①		①
24	①		①	24	①	②	①
25	①		①	25	①	②	①
26	①		①	26	①		①
27	①		①	27	①		①
28	①		①	28	①		①
29	①		①	29	①		①
30	①		①	30	①		①
31	①	↓	①	31	①	↓	①
(※) ① スートブローによる除去 (毎日実行) ② 休炉点検時における除去				(※) ① バグフィルターの逆洗による除去 (毎日実行) ② 休炉点検時における除去			